

Clarification No. 3
Solicitation for
Miscellaneous Truss & Steel Repairs
Port of Hood River
1000 East Port Marina Drive
Hood River OR,
97031

Issued: March 20, 2019.

Bid Opening Date: March 26, 2019.

Question:

Can you please clarify the length of the new handrail that is to be installed in each span that is called out for replacement.

Answer:

There was too much variation to use dimensions on the plans. 75" is a reasonable approximation for typical handrail length. Field verification is required.