



Port of
Hood River

Providing for the region's economic future.

INDUSTRIAL/COMMERCIAL FACILITIES • AIRPORT • INTERSTATE BRIDGE • MARINA

1000 E. Port Marina Drive • Hood River, OR 97031 • (541) 386-1645 • Fax: (541) 386-1395 • www.portofhoodriver.com • Email: porthr@gorge.net

Technology and Emergency Response Center (TERRC) Clarification #5

Issued: Wednesday, February 7, 2020

- 1. *Are standard ODOT street traffic rated manholes and catch basins adequate? Yes, standard ODOT traffic-rated manholes and catch basins are acceptable. 100-kip rated manholes and catch basins are not required for this project.***
- 2. *How is excavation being paid for? Is it to be included in place embankment? Yes, excavation for all areas outside of the Wetland Mitigation Pond limits, including cutbank rounding, overbreak whether avoidable or not, and foundation benching, required or necessary to perform earthwork on the embankment basis, and retrieval or removal of Cobbles and Boulders according to 00330.42(c)(2)(a) will not be measured separately and shall be considered incidental to Bid Item 9 Embankment in Place.***

Excavation for the Wetland Mitigation Pond is to be measured and paid under Bid Item 10 Wetland Mitigation Pond Excavation per 00330.81 and 00330.91. In the Wetland Mitigation Pond area only, any necessary embankment shall be considered incidental.