



Port of
Hood River

Providing for the region's economic future.

INDUSTRIAL/COMMERCIAL FACILITIES • AIRPORT • INTERSTATE BRIDGE • MARINA

1000 E. Port Marina Drive • Hood River, OR 97031 • (541) 386-1645 • Fax: (541) 386-1395 • www.portofhoodriver.com • Email: porthr@gorge.net

Big 7 Re-roof Project Clarification #1

Issued: Tuesday June 30, 2020

See questions and answers asked by potential bidders:

Q 1. Can the owner provide a photo of the roof core sample?

A 1. No, the Contractor will need to get their own core sample. Access can be coordinated with the Owner.

Q2. Will the Contractor be responsible for removing and reinstalling; electrical, lights, equipment that is currently on the roof and will need to be moved for construction?

A2. No, all electrical, HVAC modifications and equipment will be moved, removed by others. The HVAC lines will be raised by others a minimum of 8" above the new roof material.